



1. SEE SHEET FA01 FOR SYMBOL, LEGEND AND NOTES.
2. DEVICES / APPLIANCES SHOWN ON THIS SHEET ARE FOR REFERENCE ONLY. BASED ON VISUAL OBSERVATION AND AS-BUILT DOCUMENTATION (IF AVAILABLE), NOT ALL DEVICES / APPLIANCES MAY BE SHOWN. CONTRACTOR IS RESPONSIBLE TO REMOVE FIRE ALARM DEVICES / APPLIANCES AS NECESSARY TO PREPARE SYSTEM FOR NEW CONSTRUCTION.
3. IF DEVICES / APPLIANCES ARE REMOVED, CONTRACTOR SHALL REMOVE ASSOCIATED RAYS, BACKBOXES AND WIRING ABOVE CEILINGS AND BEHIND WALLS TO THE MAXIMUM EXTENT POSSIBLE.
4. CONTRACTOR SHALL VERIFY THAT DISCONNECTING EQUIPMENT / WIRING DOES NOT AFFECT OTHER FIRE ALARM SYSTEM EQUIPMENT WITHIN THE BUILDING. IF DEMOLITION AFFECTS OTHER EQUIPMENT OUTSIDE THE ZONE OF DEMOLITION, CONTRACTOR SHALL RE-CONNECT WIRING TO ANY EXISTING DEVICES TO REMAIN, EVEN IF NOT ASSOCIATED WITHIN THE ZONE OF DEMOLITION.
5. ALL REMOVED DEVICES / APPLIANCES SHALL BE RETURNED TO VA. REMOVED CONDUIT AND WIRING SHALL BE DISPOSED OF BY THE CONTRACTOR.
6. CONTRACTOR SHALL PROVIDE ALL LABOR / MATERIALS / PROGRAMMING NECESSARY FOR THE SCOPE OF WORK INCLUDED HEREIN.
7. CONTRACTOR SHALL MAINTAIN EXISTING FIRE ALARM SYSTEM IN OPERATIONAL CONDITION AT ALL TIMES UNLESS SPECIFICALLY APPROVED BY VA. EXISTING FIRE ALARM SYSTEM SHALL NOT BE TAKEN OUT OF SERVICE.

Scale: AS NOTED

[illegible]